

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MARTIN COUNTY WATER )	
DISTRICT #2 FOR A DEVIATION FROM 807 )	
KAR 5:066, SECTION 5(4), REGARDING )	CASE NO. 10496
WATER STORAGE )	

O R D E R

By letter filed on May 4, 1992, the Martin County Water District No. 2 ("Martin Water") requested additional time to comply with Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. On March 17, 1989, the Commission ordered Martin Water to bring its water storage facilities into compliance with Commission regulations by April 1, 1992.

On May 4, 1992, Martin Water informed the Commission that it has employed a consulting engineering firm, which is preparing a construction project to include 600,000 gallons of additional water storage capacity. Martin Water further stated that it needed additional time to bring its water storage facilities in compliance with Commission regulations.

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that Martin Water is making a good faith effort toward bringing its facilities into

compliance with Commission regulations and that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:


1. Martin Water be and it hereby is granted a deviation until April 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Martin Water shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to April 1, 1993.

Done at Frankfort, Kentucky, this 13th day of May, 1992.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director, Acting